

TENDER BID DOCUMENT

TENDER for

Renovation of existing 9 Nos. of 25 kWp Off-Grid SPV Power Plants at 9(nine) Deputy Commissioners' offices in Manipur including 5 years Maintenance and Performance Warranty Contract (MPWC).

NIB No. MANIREDA/SPP/DC/2019-20/16

Under

**Jawaharlal Nehru National Solar Mission
of
The Ministry of New and Renewable Energy
For the Year 2019- 20**

Manipur Renewable Energy Development Agency (MANIREDA)

2nd Floor, South Block, Secured Office Complex, A.T. Line, Near Hotel Imphal, Imphal-795001

Tele Fax : 0385-2421594, e-mail : manireda99@yahoo.com, Website : www.manireda.com

(This tender document is having 30 pages including this page)

Cost of bid document: Rs. 500/-

Contents

1. Notice Inviting Bid.....
2. Bid at a Glance
3. Detailed Notice Inviting Bid
4. General Terms & Conditions.....
5. Technical Specification.....
6. Five years Maintenance & Performance Warranty Contract (MPWC)
7. Proforma – 1 : Forwarding Letter.....
8. Proforma – 2 : Authority Letter for Signing Bid Document....
& Attending Bid Opening Meeting
9. Proforma – 3 : Information about the Bidding Firm.....
10. Proforma – 4 : Details of Orders Received and Executed in Past Years
11. Proforma – 5 : No Deviation Certificate
12. Proforma – 6 : Format for Guarantee Card
13. Proforma – 7 : Format of Completion Certificate
14. Proforma – 8 : Format for submitting the Price Schedule
15. Proforma – 9 : Application for Payment
16. Proforma – 10 : Material Inspection Clearance Certificate (MICC).
17. Check List & Format for Submission of Bid

No. : MANIREDA/SPP/DC/2019-20/16

Date: 18/11/2019

NOTICE INVITING BID

Online tenders are invited from eligible Firms for Renovation of existing 9 Nos. of 25 kWp Off-Grid SPV Power Plants at 9(nine) Deputy Commissioners' offices in Manipur including 5 years Maintenance and Performance Warranty Contract (MPWC).

Tender Specification No.	Cost of Bid Document	Last date & time for submission of Tender
NIB No. MANIREDA/SPP/DC/2019-20/16 dtd. 18/11/2019	Rs. 500/-	10/12/2019 upto 12.00 Noon Sharp

Tender Document can be downloaded from the website www.manipur.gov.in or www.manireda.com.
Bidders have to submit the Bids to the office of MANIREDA.

Last date & time of submission of Bid is 12.00 Noon of 10th of Dec., 2019

Sd/-

(L. Manglem Singh)
Director, MANIREDA

2. Bid at a Glance

NAME OF THE BIDDER : M/s
TENDER FEE DETAILS : D.D. No..... Dt
Drawn on Bank

EMD DETAILS : D.D. No..... Dt
Drawn on Bank

CMD DETAILS : D.D. No..... Dt
Drawn on Bank

SI	Description	Details
1.	Notice Inviting Bid (NIB)	MANIREDA/SPP/DC/2019-20/16 dated 18/11/2019
2.	Scope of work	Renovation of existing 9 Nos. of 25 kWp Off-Grid SPV Power Plants at 9(nine) Deputy Commissioners' offices in Manipur including 5 years Maintenance and Performance Warranty Contract (MPWC).
3.	Last date & time of submission of Bid in Hard copy.	Date : 10th December, 2019. Time : Upto 12.00 noon (submission of documents after 12.00 noon will not be accepted at any circumstances and not eligible)
4.	Date & time of opening of Technical Bid	Date : 10th December, 2019. Time : 2 .00 pm sharp. Venue : Office of the Director, MANIREDA, 2 nd Floor, South Block, Secured Office Complex, AT Line, Imphal.
5.	Cost of bid document (Non-refundable)	Rs 500/- in the form of D.D. favoring Director MANIREDA payable at Imphal. Exempted for MSME/NSIC registered Firms.
6.	Earnest Money Deposit (Refundable)	Rs. 80,000/- only in the form of D.D. favoring Director MANIREDA, payable at Imphal. Exempted for MSME/NSIC registered Firms.
7.	Caution Money Deposit (Refundable)	Rs. 1(one) lakh only in the form of D.D. favoring Director MANIREDA, payable at Imphal.
8.	Place of submission of Bid documents and address for Bid Opening Meeting.	Manipur Renewable Energy Development Agency (MANIREDA), 2 nd Floor, South Block, Secured Office Complex, AT Line, Near Hotel Imphal, Imphal - 795001. Phone No. 0385-2421594;
9.	Date & time of opening of Financial Bid	Financial Bids will be opened only for Technically qualified bidders. Date : Will be informed. Time : Will be informed.
10.	Time of completion	12 (twelve) months from the date of placement of work order for installation of new battery banks and inverters. 6(six) months from the date of placement of work order for disposal of old battery banks and inverters.
11.	Validity of offer	The offer shall remain valid up to 365 days from the date of submission of offer.
12.	Validity of earnest money	The earnest money shall be submitted by the bidder in the form of demand draft from any Nationalized/Scheduled bank. This demand draft shall have validity for at least 3 months.
13.	Notices/amendments/cancellation to be updated	Prospective bidders are requested to remain updated for any notices/amendments/cancellation, etc. in the bid document conditions/terms, in the above mentioned website. No separate notifications will be issued for such notices /amendments/ clarifications etc. in the print media (press) or intimated to the bidders separately.

3. Detailed Notice Inviting Bid (DNIB)

Manipur Renewable Energy Development Agency (MANIREDA)

2nd Floor, South Block, Secured Office Complex, AT Line, Near Imphal Hotel, Imphal-795001

Ph. : 0385-2421594, Fax : 0385-2421594, e-mail : manireda99@yahoo.com

Website : www.manireda.com

NIB No. : MANIREDA/SPP/DC/2019-20/16

Date: 18/11/2019

Sub.: Renovation of existing 9 Nos. of 25 kWp Off-Grid SPV Power Plants at 9(nine) Deputy Commissioners' offices in Manipur including 5 years Maintenance and Performance Warranty Contract (MPWC).

Dear Sir/Madam,

Manipur Renewable Energy Development Agency (MANIREDA), Imphal is inviting offer from Registered Company/Firm/Corporation in India with experience of executing contracts of Off-Grid or Grid connected Solar Power Plants for the above work with the best binding price offer as per specifications and terms & conditions mentioned in the bid document. Salient features of the bid document are given below:

CHAPTER – I: ABOUT THE BID AND ITS SUBMISSION PERIOD:

1. Bid Document

1.1 NIB No. : MANIREDA/SPP/DC/2019-20/16 dated 18/11/2019.

1.2 This Bid Document comprises of total 30 pages including Proformas. In addition, any other documents/instructions/amendments/corrigendums/revisions issued by MANIREDA to the bidder till the due date of opening of the bids shall also be deemed to be the integral part of the bid document. Failure to furnish all the information as per the bid document in every respect will be at the bidder's risk.

1.3 The Technical Bids and Financial Bids will be opened on the date and time mentioned in the tender website in the **Office of the Director, MANIREDA, 2nd Floor, South Block, Secured Office Complex, AT Line, Near Hotel Imphal, Imphal** in presence of bidders or their authorized representatives. The representative should produce authorization letter to attend the bid opening meeting in the Proforma -2.

2. Cost of Bid Document

Bidders can download the Bid Document from www.manireda.com & www.manipur.gov.in and submit the cost of the Bid document amounting Rs. 500/- (Non Refundable), along with Technical Bid. However, cost of the Bid document will be exempted for MSME/NSIC registered Firms.

3. Earnest Money Deposit (EMD)

Rs. 80,000/- only in the form of D.D. favoring Director MANIREDA payable at Imphal. The EMD will be exempted for MSME/NSIC registered Firms.

4. Caution Money Deposit (CMD)

Since the disposal of Old Battery Banks and Inverters is also an integral part of this Tender, it is compulsory for all the Bidders to submit a Caution Money Deposit (CMD) of Rs. 1(one) lakh in the form of D.D. favoring Director MANIREDA payable at Imphal. Both the EMD and CMD shall be returned to unsuccessful Bidders within 10(ten) days from the finalization of Tender.

5. Submission of Bids:

This is online Tender so Bidders are requested to upload the Price Bid in the E-tender website.

Bidders shall have to submit the Bids online & Hard copies at the office of MANIREDA within the stipulated time mentioned in Sl. No. 4 in "Bid at a Glance".

5.1 Bidders are advised to submit their bids strictly based on the specifications, terms and conditions contained in the bid document and subsequent revisions/amendments, if any.

5.2 **Only 1(one) Hard copy of Bid shall be submitted by each Bidder in Hard Bond or Spiral Binding.** The bid shall be prepared and submitted by typing or printing in English with indelible black ink on white

paper in consecutively numbered pages duly signed by the authorized signatory with company seal affixed on each page.

- 5.3 Total number of pages should be clearly mentioned and certified by competent authority.
- 5.4 Original copy of bid document, amendments/revisions to bid document, including minutes of meeting(s), issued by MANIREDA, if any, shall be signed and submitted along with the bid.
- 5.5 All the Proformas must be on the bidder's official letterhead. Any change in wording of the Proforma will lead to rejection of the bid application.
- 5.6 The offer shall contain no erasures or overwriting except as necessary to correct errors made by bidder. Such corrections, if any, shall be initialed by the person signing the offer.
- 5.7 The Bid Documents should have proper paging and flagging of Annexures/details. Documents without proper binding and proper paging etc. will not be considered in the evaluation. Any Overwriting /illegible/erasing, etc. in the documents submitted by the firms shall not be accepted.
- 5.8 Insertion, post-script, addition and alteration in Hard Copy shall not be recognized unless confirmed by bidder's signature and stamp.
- 5.9 **MANIREDA reserves the right to reject part or whole of the bid/order without assigning any reason thereof, postpone the date of receipt and opening of the bids or cancel the bid without bearing any liability, whatsoever, consequent upon such decision.**
- 5.10 Attestation of various documents enclosed along with the offer must be done by a competent authority or by the Proprietor of the Firm.
6. **Mode of Submission of Bids: Bidders have submit the Technical Bid online as well as Hard copy as stated below:**
 - 6.1 The bidder shall submit the following in Technical Bid;
 - (i) Scanned copy of Tender Fee, EMD & CMD.
 - (ii) Forwarding Letter - Proforma -1
 - (iii) Authorization letter for attending Bid Opening Meeting - Proforma-2
 - (iv) Information about the Bidding Firm- Proforma-3
 - (v) Details of Orders Received and Executed in Past 3 years. Bidders should have installed and commissioned at least one 15 kWp capacity of Off-Grid or Grid connected SPV Power plant whose work order issued in the name of the bidder to Govt. aided/Govt. Deptt./Institutions/Private Institution.
 - (vi) Test Report of ABB inverter from an MNRE approved/competent Testing Centres.
 - (viii) Test Report for Battery/Battery Bank to be supplied from an MNRE approved/competent Testing Centres.
 - (ix) **Company Warranty Certificate of Battery/Battery Bank to be supplied for a period of 5 years from the Battery Manufacturer.**
 - (x) A summarized sheet of turnover for last 3 yrs certified by registered Chartered Accountant.
 - (xi) Letter of authorized dealer/service provider in Manipur
 - (xii) ISO 9001 certificate.
 - (xiii) ISO 14001 certificate.
 - (xiv) GST Registration Certificate of Company/Firm.
 - 6.2 The hard copy of Technical Bid should be submitted in a sealed envelope superscribed "NIB No.: MANIREDA/SPP/DC/2019-20/16 (Technical Bid)", to the office of MANIREDA, 2nd Floor, South Block, Secured Office Complex, AT Line, Near Hotel Imphal, Imphal-795001 addressed to Director, MANIREDA. This envelope should contain the following:
 - (i) Cost of bid document.
 - (ii) Original EMD/CMD by demand Draft of requisite value.
 - (iii) Technical Bid should not contain price of any item. Such cases, even if found anywhere, shall not be given any cognizance.
 - 6.3 The hard copy with earnest money and cost of tender document has to be submitted during the period upto 12 noon of 10th December, 2019 failing which no late comers would be strictly entertained.
 - 6.4 The Bidders should furnish the Authorization letter as per Proforma – 2 with the seal of the company for

the person attending the Bid Opening meeting & signing the bid document.

- 6.5 A person signing the bid document or any document forming part of the bid document shall be deemed to warrant that he has authority to bind such offer/ document and if on enquiry it appears that the person signing had no authority to do so, MANIREDA may, without prejudice to other civil and criminal remedies, cancel the bid/contract and hold the signatory liable for all costs and damages.

CHAPTER – II: ELIGIBILITY CRITERIA

8.0 Eligibility and Qualification Criteria

8.1 The bidder should be:

A Registered Company/Firm/Corporation in India with supporting documents. Cumulative Experience of the Bidders should be of executing contracts of Off-Grid or Grid connected Solar Power Plants (installed & commissioned). The Bidders should have designed, supplied, installed & commissioned and tested a minimum of 15 kWp Off-Grid or Grid connected Solar Power Plant in Govt. aided/Govt. Institution/ Private Institution etc. with

8.2 Bidder should have Test Certificate of Battery Bank to be installed from an approved/competent testing centres as per requirements under the JNNSM scheme of the MNRE, GOI.

8.4 The Bidder should have provide the Company Warranty Certificate of Battery/Battery Bank to be supplied for a period of 5 years from the Battery Manufacturer during the Technical Bid otherwise the bid is liable to be rejected.

8.5 Cumulative Turnover of the Company/Firm/ Corporation in the last three financial years (2016-17, 2017-18 & 2018-19) should be at least 50 lakhs. This must be the individual Company's turnover and not that of any group of Companies. (A summarized sheet of turnover certified by registered CA should be compulsorily enclosed)

8.6 The Bidder should have registered office/authorized dealer/service network in Manipur. Details of the authorized dealer viz. name, address, contact no. both mobile and landline, e-mail ID etc. should be enclosed.

- Bidders who do not have service network in Manipur should be willing to appoint within 15 days from the date of Work Order and the details should be submitted. A self declaration on the same should be submitted with the Bid document.

- Trained manpower, proper infrastructures with adequate spares should be maintained in the office for smooth execution of MPWC.

8.7 The Bidder should have valid GST registration certificate. A copy of which should be enclosed.

8.8 The bidder should have ISO 9001 certification

8.9 The bidder should have ISO 14001 certification.

CHAPTER – III: SCOPE OF WORK

9.0 Scope of Work

9.1 The scope of work is to Renovate the existing 9 Nos. of 25 kWp Off-Grid SPV Power Plants at 9(nine) Deputy Commissioners' offices in Manipur including 5 years Maintenance and Performance Warranty Contract (MPWC).

(a) The 1st Work involves the supply, installation & commissioning of 15 kWp Off-Grid SPV Power Plants at 9(nine) Deputy Commissioners' offices in Manipur including 5 years Maintenance and Performance Warranty Contract (MPWC) with installation of new battery banks of flooded type low maintenance lead acid battery of capacity 48V 500 Ah and 15 kW ABB Micro Grid Inverters.

(b) The 2nd Work involves the disposal of old battery banks and Inverters at the existing condition.

9.2 MANIREDA reserves the right to amend the scope of work, accept or reject any or all the offers/bids, in part or in full or cancel/withdraw the invitation for bids without assigning any reasons whatsoever and in such case, the bidder/intending bidder shall have no claim arising out of such action.

The Bidder shall carefully check the specifications and shall satisfy himself regarding the technical requirement and completeness of the equipment/system. MANIREDA shall examine whether the bid is complete in all respects and conform to the stipulated requirement of the technical specifications and tests reports. The bid having material deviation shall be rejected as being non-responsive. If any amendment in specification is made by MNRE during implementation of this project, the same shall be followed by MANIREDA.

- 9.3 The bidders should beforehand thoroughly familiarized with the site to be installed, incidental expenditures/charges on transportation, installation and maintenance expenses etc. They should also access the local conditions including prevailing law and order problems before submitting their offer. Any claim on change/increase in the rate/cost of the work due to any reason will not be entertained at any circumstances.
- 9.4 MANIREDA, if required, may at its discretion obtain clarifications on offers by requesting clarifications from any or all the bidders at any time prior to Financial Bid opening. Such request for clarification and the response shall be in writing.
- 9.5 It is not necessary to select the lowest quoted rate. MANIREDA reserves the right to decide the reasonable price/rate for successful implementation of the project.
- 9.6 The Financial Bid of only those bidders, whose Technical Bids are found qualified after evaluation, will be opened and evaluated. In case of deviation in the date and time of opening of the Financial Bid from what is given in the Bid Detail, the date & time for opening of the Financial Bid will be uploaded on MANIREDA website. Bidders are requested to visit the website (www.manireda.com) regularly and keep themselves informed.
- 9.7 The bidders shall be ranked **L1, L2, L3** etc. as per the **Part A of Proforma – 8** and **H1, H2, H3** etc. as per the **Part B of Proforma – 8**. The work order will be issued subject to the acceptance of the bidders to supply at approved rate. MANIREDA reserves the right to award more than one firm for execution.

10.0 Price

- 10.1 The Bidder shall quote price as per Proforma – 8.
- 10.2 **There are 2(two) Financial /Price Bids, Part A and Part B of Proforma – 8 in this Tender. It is compulsory for all the Bidders to quote both the Financial Bids i.e. Part A and Part B of Proforma-8. The Bidder quoting any one Part of Proforma – 8 is liable to be rejected.**
- 10.3 The award of Work may be separate for each Price Bid depending upon outcome of each Price Bid.
- 10.4 **Lowest Bidder (L1)** will be accepted for the Price Bid (**Part A of Proforma-8**).
- 10.5 **Highest Bidder (H1)** will be accepted for this Price Bid (**Part B of Proforma-8**).
- 10.6 In case, if the same Bidder becomes **L1** of Price Bid (Part A of Proforma-8) and **H1** of Price Bid (Part B of Proforma-8) then the settlement of Accounts or Award of Works will be based on Net Amount i.e. Lowest Amount (L1) quoted by the bidder less the Highest Amount (H1) quoted by the same bidder.
- 10.7 If the Bidders are different for **L1** of Price Bid (Part A of Proforma-8) and **H1** of Price Bid (Part B of Proforma-8) then the Works will be awarded separately to different Bidders.
- 10.8 **In case, if the Price offered in Price Bid (Part B of Proforma-8) is same for more than one bidder then the Lowest Bidder (L1) of Price Bid (Part A of Proforma-8) will become the successful bidder for both the Works.**
- 10.9 The successful Bidder (H1) for the Price Bid (Part B of Proforma-8) shall have to deposit the amount within 20(twenty) days from the issue of Work Order in the form of DD in favour of Director, MANIREDA payable in Imphal.

CHAPTER – IV: PAYMENT TERMS

11.0 Terms of Payment (For Part A of Proforma-8)

- 11.1 20% of the total work order value (excluding installation, commissioning and MPWC cost) shall be released as mobilisation advance against the submission of Bank Guarantee of equivalent amount from a Nationalised Bank/ Scheduled Bank valid at least for a period of 6 months after

verification subject to availability of fund. The mobilisation advance so paid shall be interest bearing @ 9% per annum effective from the day on which advance payment is made.

- 11.2 50% of the total work order value (excluding installation, commissioning and MPWC charges) or 70% if the mobilisation advance is not taken for each bill shall be released against delivery of goods in full and in good condition subject to availability of fund and after submission of :-
- 11.2.1. Certificate of supply of grid connected solar power plant received by the consignee as specified.
- 11.2.2. Commercial invoice of the supply made in triplicate.
- 11.2.3. Copy of delivery challan/transportation challan/lorry receipt
- 11.2.4. Material Inspection Certificate.
- 11.3 Remaining 30% of the contract price (excluding installation, commissioning and MPWC charges) and 100% of installation, commissioning charges shall be paid against duly verified completion report with successful installation and commissioning including erection and testing of the systems after submission of the following documents:
- 11.3.1. Certificate of installation, commissioning, integration to grid and testing of grid connected solar power plant.
- 11.3.3. Commercial invoice of the supply made in triplicate.
- 11.3.4. Copy of delivery challan/transportation challan/lorry receipt.
- 11.3.5. Verification of Certificate of Commissioning and testing from the consumer/ beneficiary countersigned by officer concerned.
- 11.3.6. Photographs along with details of module, inverter/PCU, metering etc. installed.
- 11.3.7. All payments shall be released by MANIREDA through e-payment through RTGS/account transfer for which the following mandatory information is to be furnished from the consumer;

Name of the Firm to whom payment is to be made	Name of bank	Bank Branch address	Account Number	Type of account	MICR Code	IFSC code	PAN No.
--	--------------	---------------------	----------------	-----------------	-----------	-----------	---------

Performance Guarantee

- 11.4 The contractor has to deposit @5% of the project cost (excluding MPWC cost) as **Performance Guarantee in terms of irrevocable Bank Guarantee for the tenure of the contract including MPWC period.** For the successful bidders, the EMD/CMD submitted may also be adjusted as part of the Performance Guarantee, but the firm has to submit the balance in the form of BG to make requisite 5% Performance Guarantee. If the Solar system fails to conform to the laid down systems specifications or any deviation/compromise has been observed in the system specifications etc., the performance guarantee deposit of the firm shall be forfeited.
- 11.5 MPWC charges shall be released on 5 equal yearly installments on satisfactory performance. The record of performance sheet/metering system duly attested by the Beneficiaries shall be submitted to MANIREDA on quarterly basis, by 15th of the next month.

CHAPTER – V: GENERAL TERMS AND CONDITIONS

12.0 No Claim or Compensation for Submission of Tender.

- 12.1 The bidder whose bid is not accepted shall not be entitled to claim any costs, charges, expenses and incidental incurred by him through or in connection with his submission of bid, even though MANIREDA may decide to withdraw the notice inviting bid.

13.0 Validity of Offer

- 13.1 Unless otherwise specified, the bidder shall keep his tender valid initially for a period of 365 days from the due date of submission of the offer.

14.0 Award of Contract/Work Order

- 14.1 The contract/work order shall be awarded to the bidder whose financial Bid was acceptable and who is selected by the Tender Committee of MANIREDA/Departmental Tender Committee to undertake the

work at the approved rate and on approval of the Chairman, MANIREDA.

14.2 In case, if the same Bidder becomes **L1** of Price Bid (Part A of Proforma-8) and **H1** of Price Bid (Part B of Proforma-8) then the settlement of Accounts or Award of Works will be based on Net Amount i.e. Lowest Amount (L1) quoted by the bidder less the Highest Amount (H1) quoted by the same bidder.

14.3 If the Bidders are different for **L1** of Price Bid (Part A of Proforma-8) and **H1** of Price Bid (Part B of Proforma-8) then the Works will be awarded separately to different Bidders.

15.0 Effective Date of Contract

15.1 The effective date of commencement of execution of the order by the selected contractor shall be the date of issue of the Purchase/Work Order whichever is earlier.

16.0 Contract Price

16.1 The total contract price should include a detailed break up of cost for supply of each materials such as control electronics, inverter, energy meter, mechanical components, etc. including 5 years MPWC in Proforma – 8. The price shall be for the total scope as defined in this document.

16.2 The income tax shall be deducted as applicable at the existing rate.

16.3 During the period of the contract, MANIREDA may order addition/deletion in quantities/capacities which the bidder shall comply. The adjustment in Contract Price shall be made at the same unit rate as per **Price Schedule (Proforma – 8)**.

17.0 Statutory Variations in Taxes and Duties:

17.1 The adjustment in the Contract Price towards imposition of new taxes or abrogation of existing taxes due to statutory variation shall be applicable only if the new tax is enacted or existing tax is abrogated within contractual delivery/execution period. For any upward variation due to enactment of new tax or abrogation of existing tax after contractual delivery/execution period, adjustment in the Contract Price shall not apply, although for any downward variation, MANIREDA shall make necessary adjustment in the rate of the items.

17.2 The Supplier shall bear and pay all liabilities in respect of statutory variations in taxes and duties and imposition of new taxes and duties that may be imposed after the contractual delivery/execution dates, as originally stipulated, in case the delivery dates are extended due to reasons attributable to Supplier.

18.0 Agreement:

18.1 The Supplier/Contractor(s) have to enter into an agreement within two weeks, in the office of the Director, MANIREDA in prescribed format before commencement of supply/services.

19.0 Dispatch Instructions:

19.1 All items/equipments may be subjected to pre-dispatch inspection by Director, MANIREDA or its authorized representative(s) as per relative standards/provisions approved by MANIREDA before dispatch of items. Cost of inspection by officials (not more than two) would be borne by the successful bidder.

20.0 Transit Insurance:

20.1 Transit Insurance shall be arranged by the Supplier for his total supplies. In case of any damage/loss/pilferage/non-delivery during transit, the Supplier shall lodge the claim and settle the claim with the insurance agency. The Supplier shall also arrange replacement of the damaged, lost/pilfered items expeditiously pending settlement of commercial implications with insurance agency, if any, so as not to hamper the working of the system. The resultant loss if any due to failure of Supplier to comply with the above shall be to the account of the Supplier.

21.0 After Sales Service and Availability of Spare Parts:

21.1 The Supplier shall depute authorized Service Engineer within 3 days from the date of the intimation of fault, and establish sufficient inventory of spares, well trained technicians in the State in consultation with MANIREDA to provide satisfactory and uninterrupted services during the guarantee/ MPWC period for which a servicing centre must be established at Imphal. Details of the Servicing centre such as Name, Address, Contact number etc. of the Firm must be submitted to MANIREDA before commencement of the work.

22.0 Completion Schedule:

- 22.1 The Project for installation of new Battery Banks and Inverters shall be completed in full as per the terms and conditions of the contract within **12 (Twelve) months** from the date of issue of the Work Order.
- 22.2 The Project for disposal of old Battery Banks and Inverters shall be completed in full as per the terms and conditions of the contract within **6 (Six) months** from the date of issue of the Work Order.
- 22.3 The successful Bidder (H1) for the Price Bid (Part B of Proforma-8) shall inform MANIREDA beforehand about the disposal the old Battery Banks and Inverters and dispose the old Battery Banks and Inverters in the presence of Scheme Officer/official of MANIREDA.

23.0 Guarantee/Warranty Period:

- 23.1 The Firm must provide guarantee which include servicing & replacement guarantee for the newly installed components.
- 24.2 Supplier/contractor shall without prejudice to any other clauses of the order repair/replace the defective parts and restore the system to satisfactory working/performance within 7(seven) days of intimation of fault without any additional cost to MANIREDA within the period of guarantee/ MPWC.

25.0 Assignment/Sub Letting/Pre Bidding Tie Up:

- 25.1 The Supplier/contractor shall not assign or sub let, manufacture, shop testing, packing & forwarding, transportation, transit insurance and supply, in whole or part, its obligations to any third party to perform under the order/contract.
- 25.2 In the event the Supplier contravenes this condition, MANIREDA reserves the right to reject the equipment/work sub-contracted and procure the same from elsewhere at Supplier's risk and cost. The Supplier shall be solely liable for any loss or damage which MANIREDA may sustain in consequence or arising out of such replacing of the contract work.
- 25.3 In case, the installation & commissioning and MPWC is planned to be carried out in collaboration with other party, the bidder has to sign MoU with the party on a Non-judicial stamp paper of value not less than Rs. 100/- and submit a copy of the MoU along with the bid. The MoU shall clearly indicate division of scope of work between the prime bidder and his sub-vendor and terms of payment. However, the total responsibility of work will remain with the prime bidder.

26.0 Liquidated Damages for Delay in Completion:

- 26.1 The completion period for the assignment must carefully be worked out and all resource & work planning is to be done accordingly with flexibility for adjustments.
- 26.2 If the Supplier fails in the due performance of the contract to deliver and commission any part of the equipment or complete the work within the scheduled date for any reason other than due to Force Majeure conditions or any extension thereof granted to him by MANIREDA, he shall be liable to pay to MANIREDA as pre-agreed liquidated damages but not by way of penalty on account of delayed successful commissioning, a sum equal to 0.1% of total contract value per week of such delay, or part thereof, subject to maximum of 5% of the Total Contract Value.
- 26.3 The liquidated damages for delayed completion shall be recovered from the Supplier's Bill / Bank Guarantee deposited as Performance Guarantee.
- 26.4 Deductions/payment of liquidated damages shall in no way relieve the Supplier from his contractual responsibility to complete the works.

27.0 Cancellation of Order:

- 27.1 MANIREDA will be at liberty to terminate in part or full the awarded contract without prejudicing its rights and affecting the obligations of the Contractor by giving seven (7) days notice in writing in the following events:
- (a) If the Supplier is found defaulter for delayed supply or failure to deliver satisfactory performance or supply of substandard materials pursuant to NIB conditions.
 - (b) If the Supplier/Vendor fails to comply with the provision(s) of the contract including the responsibilities to fulfill the 5 years maintenance and performance warrantee contract as per the provisions mentioned in this bid document.
 - (c) If the Supplier/Vendor is involved in any action of moral turpitude.

28.0 Arbitration:

- 28.1 All disputes or differences, whatsoever, arising between the parties out of or in relation to the construction, meaning and operation or effect of this contract or breach thereof shall be settled amicably.
- 28.2 If, however, the parties are not able to resolve them amicably, the same shall be settled by arbitration in accordance with the Rules of Arbitration of the Indian Council of Arbitration and Conciliation & Arbitration Act 1996 and the award in pursuance thereof shall be binding on the parties.
- 28.3 The venue of arbitration proceeding shall be within Jurisdiction of Court of Law at Imphal only.
- 28.4 Work under this contract shall be continued by the Supplier during the arbitration proceedings, unless otherwise directed in writing by MANIREDA or unless matter is such that the work cannot possibly be continued until the decision of the Arbitrator is obtained.

29.0 Force Majeure:

- 29.1 Should at any time during the continuance of the contract the performance in whole or in part of any obligations by either party under this contract be held up by reasons of any war, hostility, civil commotion, sabotage, fires, floods, earthquakes, explosions, epidemics, cyclones, quarantine restrictions, Governmental regulations, law & order and other proclamation etc. (hereinafter referred to as "Events") then, provided notice of the happening of any such eventuality is given by either party to the other within 15 days from the date of occurrence thereof neither party shall, by reasons of such eventuality, be entitled to terminate this contract, nor shall either party have any claim for damages against the other in respect of such non-performance or delay in performance, and the work under this contract shall be resumed as soon as practicable after such eventuality has come to an end or ceased to exist.
- 29.2 Should one or both the parties be prevented from fulfilling their contractual obligations by a state of force majeure, lasting continuously for a period of at least four (4) weeks, the two parties should consult each other regarding the further implementation of the contract.
- 29.3 The above-mentioned force majeure conditions/clause shall also apply in the works of sub-contractors/suppliers of the contractor.
- 29.4 However, the Supplier shall not be liable for liquidated damages or termination/ cancellation of order/contract if and to the extent that its delay in performance or other failure to perform its obligations under the contract is the result of an event of force majeure.

CHAPTER – VI: TECHNICAL SPECIFICATIONS

The proposed projects shall be commissioned as per the technical specifications given below. Any shortcomings will lead to cancelation of subsidy in full or part as decided by MANIREDA & Competent Authority's decision will be final and binding on the bidder.

1. SOLAR PHOTOVOLTAIC MODULES

- 1.1 Existing Solar Modules shall be utilized for renovation of the plant.
- 1.2 The output of renovated plant should be of 15 kW which requires 24 kW Solar PV input. So, the SPV capacity should be of 25 kW.
- 1.3 The Bidders may access the actual conditions of the SPV Modules. In case, if any SPV Module/Modules is or are found defective then it/they shall be replaced with new ones. Therefore, the Bidders shall include the cost of maximum quantity of 10 Nos. of SPV Modules.
- 1.4 Each and every solar module shall have to be cleaned first before commissioning of the plant and should be free from grime and dirt.

2. PCU/ Inverter:

- 2.1 The old PCU/Inverters of DC offices shall have to be disposed off by the successful Bidder/Contractor.
- 2.2 Make of old PCU/Inverters: 1. **Emerson** (6 Nos.)
Model: Liebert ESU 30 kW 030-Bidirectional
2. **Optimal** (3 Nos.)
Model: GSC-25K (3P-0D-230-50-240-25K)MPPT

2.3 The successful Bidder/Bidders shall remove the old Inverters from the DC offices and supply & install the new Inverters for each SPV Power Plant at 9 DC offices of following specifications:

Make : ABB.

Type: Micro Grid Inverter (Hybrid Inverter).

Capacity: 15 kW.

Model: MGS100-15.

Technical features:

Rating	15 kW
General Data	
Nominal load power	15 kW
Max. PV output power	22.5 kW
Max. PV input power	Upto 30 kWp (10kWp or 18.6A for MPPT1, 20kWp or 37.2A for MPPT2 whichever is higher)
Max. no. of power modules in parallel	6
Max. battery charging power	14.4 kW
PV Input	
Max. PV input DC voltage	900 VDC
PV input current protection	Yes
Working Dc Voltage range	350 VDC to 900 VDC
MPPT voltage range	350 – 800 VDC
Start-up voltage/Initial feed-in voltage	320 VDC / 350 VDC
Number of MPPT	PV1: 2x18.6, PV2: 18.6
PV input voltage protection	Yes
Max. Inv. Backfeed current to array	0 Amps
AC Input	
Nominal input voltage	3 × 400/230 V + N
Auto Restart Voltage	180 VAC per phase
Acceptable Input Voltage Range	170– 280 VAC/phase
Input frequency	50 / 60 Hz
Frequency tolerance (Via grid input)	±5%
AC Input Power	15000 VA / 15000 W
Maximum AC Input Current	40 A
Inrush Input Current	40 A / 1 ms
GENERATOR INPUT	
Voltage input from Diesel Generator	3 × 400/230 V + N
Acceptable Input Voltage Range	170 to 280 VAC per phase
Acceptable Input frequency Range	40.0 to 60.0 Hz
Maximum AC Input current	40 A
Maximum export power via grid input	15 kW
Output	
Nominal output voltage	230 VAC (P-N) / 400 VAC (P-P)
Output voltage range (grid section)	184 – 264 VAC/phase
Output voltage variation (generator section)	±1%
Output frequency	47.5 to 51.5 Hz or 59.3 to 60.5 Hz
Permissible unbalanced p-p load	100%
Nominal Output Current	21.7 A
Inrush Current/Duration	25.5 A per phase / 20 ms
Maximum Output fault Current/ Duration	68 A per phase / 1 ms
Maximum output overcurrent protection	68 A per phase
Power Factor Range	0.9 lead – 0.9 lag

Insulation Level	Transformer less
Output voltage protection	Yes
Battery	
Nominal battery voltage	48VDC
Battery type	Lead Acid, VRLA, Li-ion, Tubular Gel, Etc.
Maximum battery charging current	Default – 90A, (10A-300A adjustable)
BATTERY MODE OUTPUT (AC)	
Nominal Output Voltage	230 VAC (P-N/ 400 VAC (P-P)
Output Frequency	50 Hz / 60 Hz (auto sensing)
Output Webform	Pure sine wave
Output Power	91 %
Efficiency (DC to AC)	< 15 ms (On-Grid mode to off-grid mode)
Transfer Time	≤ 50 ms (On-Grid mode to Off-grid mode)
Transfer time in parallel mode	
Environmental	
Humidity	<90% (Non-condensing)
Ambient temperature (Without derating)	-5 to 50 °C
Temperature derating	After 50 °C at 1% every degree
Operating ambient temperature range	-10 °C to +55 °C
Altitude	1000 m
Altitude derating	After 1000 m at 1% every 100m
User interface & remote monitoring	
HMI	Graphical display for control & monitoring
Local & remote monitoring	Yes (Optional), via Wi-Fi/GSM card
Communication Protocol	Via RS232/USB for PC Tool Monitoring and CAN interface for Parallel of Inverter
Other interfaces (Optional)	SNMP/MODBUS
Physical	
Dimension (W x D x H) mm	~ 650 x 224 x 974
Net weight (kgs)	<75
IP Protection	IP21
Certification	
Safety EMC Standard & Climate	IEC 62116
	IEC61727
	IEC62109-1
	IEC 62109
	IEC61000-6-1
	IEC61000-6-3
	IEC61000-3-11
	IEC61000-3-12
	IEC61683
	IEC60068-2-(1,2,6,14,27,30,75,78)
	EN50530

The successful Bidder/Contractor shall also provide necessary items in the Inverters in order to enable the inverters to export excess energy to the Grid.

3. **BATTERY BANK:**
 - 3.1. **The old Battery Bank of DC offices shall be disposed off by the successful Bidder/Contractor.**
 - 3.2. **The successful Bidder/Contractor shall remove the old Battery Bank from the DC offices and supply & install the new sets of Battery Bank of capacity 48V 500 Ah for each SPV Power Plant at 9 DC offices.**

- 3.2 The battery bank should comprise of **24 numbers of 2 Volt 500Ah** (under standard test condition) of **Flooded type, low maintenance, tubular plate lead-acid stationary battery** having long service life (minimum five years) for each of the 9 DC offices. The cells shall be capable of deep discharges and frequent cycling with long maintenance intervals and high coulombic efficiency.
- 3.3 The Storage Batteries/Battery Bank must conform to the latest edition of IEC/equivalent BIS Standards as specified below:
- | | | |
|--|---|---------------|
| General Requirements & Methods of Test | - | IEC 61427 |
| Tubular Lead Acid | - | IS 1651: 1991 |
- 3.4 **Warranty:** The Storage Batteries/Battery bank must be warranted for 5 years from date of commissioning i.e. Any battery damaged or defunct within this period (5 years from the date of commissioning) shall be replaced by the successful bidder/Contractor with a new one of same make and configuration.
- 3.5 The permitted maximum deep discharge (DOD) shall be specified by the supplier in the offer. Unless otherwise specified, the cycle life of the battery shall not be less than 1200 charge-discharge cycles between fully charged state and the permitted maximum DOD at a rate of C/10, end of life shall be 80% of the rated capacity. Each battery shall be fitted with explosion proof safety vents.
- 3.6 All technical and other details pertaining to the storage cells shall be supplied including but not limited to the following:
Rated voltage and Ampere-hour capacity of each storage cells and their rated discharge rate; Permitted maximum DOD; ii) Self discharge rate; iii) Cycle life of the storage cells and anticipated life of the battery banks; iv) Instructions on first time charging including specification of the battery charger; v) Details on cell connections; and vi) Safety procedures.
- 3.7 One set of battery maintenance tools consisting of Thermometer, Cell Tester, Hydro Meter, Acid & Distilled water pouring containers of required size, battery connection leads, Acid Proof Hand Gloves, Gumboots and one set of hand tools suitable for making battery connections to be supplied with the Battery Banks.
- 3.8 **Battery Rack:** Suitable size and strong battery rack should be supplied with each battery banks. The placement of battery should be such that maintenance of battery could be carried out easily.
- 3.9 **Manufacturer:** Exide Industries Ltd (EXIDE)/ HBL Power Systems Ltd (HBL)/ Accumulator Manufacturing Co. (AMC) etc. or equivalent approved by MNRE, GoI providing a Company Warranty of 5 years from the date of commissioning of the SPV power plants.
4. **ARRAY STRUCTURE**
Existing array structure shall also be utilized for this plant.
6. **JUNCTION BOXES (JBs):**
Existing Junction Boxes (JBs) and Sub Junction Boxes (SJBs) shall be utilized for renovation of the plant. The successful Bidder/Contractor has to check all the Junction Boxes (JBs) and Sub Junction Boxes (SJBs) and if any JB or SJB is/are found defective by successful Bidder/Contractor, it/they shall be replaced with new ones.
7. **DC DISTRIBUTION BOARD (DCDB):**
Existing DC Distribution Board (DCDB) shall be utilized for renovation of the plant. The successful Bidder/Contractor has to check all the DCDBs and if any fault is found in DCDB, the successful Bidder/Contractor shall rectify it.
8. **AC DISTRIBUTION PANEL BOARD (ACDB):**
Existing AC Distribution Board (ACDB) shall be utilized for renovation of the plant. The successful Bidder/Contractor has to check all the ACDBs and if any fault is found in ACDB, the successful Bidder/Contractor shall rectify it.
- 8.. **REMOTE MONITORING**
Remote Monitoring and data acquisition through Remote Monitoring System software shall be provided which can be accessed online at MANIREDA.
9. **PROTECTIONS:**

The protection of Grid connected SPV power plant is an important feature.. The system should be provided with all necessary protections like earthing, Lightning, and grid islanding as follows:

9.1. **LIGHTNING PROTECTION**

Existing Lightning protection system shall be used. However, the successful bidder should ensure that it is fully functional otherwise he should rectify it to make it fully functional before the commissioning of the plants.

9.2. **SURGE PROTECTION**

Existing surge protection system shall be used. However, the successful bidder should ensure that it is fully functional otherwise he should rectify it to make it fully functional before the commissioning of the plants.

9.3. **EARTHING PROTECTION**

Existing Earthing protection system shall be used. However, the successful bidder should ensure that it is fully functional otherwise he should rectify it to make it fully functional before the commissioning of the plants.

10. **CABLES:**

Existing cables shall be used. However, the successful bidder should ensure that it is fully functional otherwise he should rectify it to make it fully functional before the commissioning of the plants. New PVC pipes shall be installed for laying of cables from SPV Array to DCDB by the successful bidder.

11. **TOOLS & TACKLES AND SPARES:**

- a) After completion of installation & commissioning of the power plant, necessary tools & tackles are to be provided free of cost by the bidder for maintenance purpose. List of tools and tackles to be supplied by the bidder for approval of specifications and make from MANIREDA/owner.
- b) A minimum set of spares shall be maintained in the plant itself for the entire period of warranty and Operation & Maintenance which upon its use shall be replenished.

12. **FIRE EXTINGUISHERS:**

The fire fighting system for the proposed power plant for fire protection shall be consisting of:

- a) Portable fire extinguishers in the control room for fire caused by electrical short circuits.
- b) Sand buckets in the control room.
- c) The installation of Fire Extinguishers should conform to TAC regulations and BIS standards. The fire extinguishers shall be provided in the control room housing PCUs as well as on the Roof or site where the PV arrays have been installed.

13. **SAFETY MEASURES:**

The bidder shall take entire responsibility for electrical safety of installation(s) including connectivity with Grid and follow all the safety rules & regulations applicable as per Electricity Act, 2003 and CEA guidelines etc.

CHAPTER–VII: FIVE YEARS MAINTENANCE & PERFORMANCE WARRANTY CONTRACT (MPWC)

The Maintenance and Performance Warranty Contract (MPWC)

- a. After the works are awarded to the successful Bidder/Bidders, he/they enter into a Maintenance & Performance Warranty Contract (MPWC) with MANIREDA which includes the scope of operation and maintenance of the SPV Power Plant for a period of 5(five) years. The date of MPWC period shall begin from the date of actual commissioning of the Solar Power Plant. The Maintenance & Performance Warranty Contract shall include servicing & replacement guarantee for parts and components (such as electronics, PCU/Inverter, etc.) of Solar Power Plant for 5 years from the date of installation. For PV modules, the replacement guarantee is for 20 years.
- b. The Contractor should keep a trained person permanently (present round the clock) for day today operation, troubleshooting, maintenance etc. at the SERVICE CENTRE for attending any fault as and when occurred.
- c. The maintenance service provided shall ensure proper functioning of the grid connected rooftop SPV

Power Plant as a whole. All preventive/routine maintenance and breakdown/corrective maintenance required for ensuring maximum uptime shall have to be provided by the Contractor. MANIREDA will provide the format of Maintenance sheet for submitting the Performance Report quarterly. The Contractor shall furnish a Performance Report duly attested by the Beneficiary alongwith the hard copy/printout of the daily performance data of the Plant for every quarter (3 months) shall be submitted to MANIREDA quarterly within 15th day of following month during the MPWC period. The MPWC shall have two distinct components as described below.

2.0 Preventive/Routine Maintenance

2.1 This shall include activities such as, cleaning and checking the health of the SPV Power plant, cleaning of module surface, tightening of all electrical connections, changing of tilt angle of module mounting structure, and any other activity that may be required for proper functioning of the SPV Power Plant as a whole.

3.0 Breakdown/Corrective Maintenance

3.1 Whenever a complaint is lodged by the consumer, the bidder shall attend to the same within a reasonable period of time 3 days and in any case the breakdown shall be corrected within a period not exceeding 7 days from the date of complaint.

3.2 The bidder shall maintain the following facilities at the local Service Centre for ensuring highest level of services to the end user;

(i) Adequately trained manpower, specifically trained by the bidder for carrying out the service activities.

(ii) Adequate provisions for record keeping, which shall inter-alia, include the following:

(a) Details of system supplied within the command area of the service station including full name and address of consumer, system and sub-system serial numbers and records of routine maintenance carried out (duly signed by the consumer). These records shall include voltage, current, specific gravity, indicator charge, inverter operation, electronics, etc.

(b) History record sheets of maintenance done.

(iii) Adequate spares and manpower for ensuring least down time of an individual system.

(iv) The Service Center shall send summary service reports to MANIREDA on quarterly basis.

These reports shall include the following information:

(a) Number/Type of components of the Plant covered by the Service Center.

(b) Number/Type of components/systems working satisfactorily on the reporting date.

(c) Number of complaints received during the period of reporting.

(d) Number of complaints attended during the period of reporting.

(e) Major cause of failure, as observed

(f) Major replacement made during the reporting period. Separate report shall be submitted for each type of systems manufacture wise in case the service center caters to the requirement of more than one manufacture

(g) Hard copy/printout of the daily performance data of the Plant for the last quarter.

3.3 The records maintained at the Service Center shall be available from time to time to MANIREDA.

3.4 The date of MPWC maintenance period shall begin on the date of actual commissioning of the SPV systems. If during the MPWC period, the Solar Power Plant becomes non-functional due to any defect or shortage of spares etc. for a period more than 1 week then the time duration of this non-functional period will be extended in the MPWC period.

3.5 Any payment for release of MPWC charges will not be entertained or put up to Higher Authority of MANIREDA without the Performance Report duly attested by the authority of Beneficiary.

3.6 Bidder shall furnish details of infrastructure that are presently available for establishing of Service Centers.

7. Proforma – 1

Forwarding Letter

NIB No.: MANIREDA/SPP/DC/2019-20/16

Date:.....

To,

The Director
Manipur Renewable Energy Development Agency (MANIREDA),
2nd Floor, South Block, Secured Office Complex, AT Line, Near Imphal Hotel,
Imphal - 795001.

Sub: Offer in Response to Notice Inviting Bid No. MANIREDA/SPP/DC/2019-20/16 for;
Renovation of existing 9 Nos. of 25 kWp Off-Grid SPV Power Plants at 9(nine) Deputy Commissioners' offices in Manipur including 5 years Maintenance and Performance Warranty Contract (MPWC).

Sir,

With reference to the above we are submitting this offer after having fully read and understood the nature of the work and having carefully noted all the specifications, terms & conditions laid down in the bid document. This offer is hereby submitted in sealed envelopes duly marked as indicated below:
(Technical Proposal): Submitted in original

The Financial Proposal is submitted online in e-tender

We also confirm that:

1. We are an Indian company/firm.
2. We have never been debarred from executing similar type of work by any Central/ State/ Public Sector Undertaking/Department/Nodal Agency.
3. The Bid Document is downloaded from MANIREDA website and necessary document in support is enclosed.
4. We shall execute the offer/work order as per specifications, terms & conditions of the Bid Documents on award of work.
5. Our offer shall remain valid for placement of purchase orders up to 365 days from the due date of submission of offer.
6. If at any time, any of the declarations submitted by us is found to be false, our offer or order is liable to rejection.

Yours faithfully,

(Signature of Authorized Signatory)

Name :
Designation :
Company Seal :

8. Proforma – 2

Authority Letter for Attending Bid Opening Meeting & Signing Bid Document

NIB No.: MANIREDA/SPP/DC/2019-20/16

Date:.....

To,

The Director

Manipur Renewable Energy Development Agency (MANIREDA),
2nd Floor, South Block, Secured Office Complex, AT Line, Near Hotel Imphal,
Imphal-795001.

Sub: Authority Letter for Attending Bid Opening Meeting & Signing Bid Document.

I hereby authorize (Name & Designation) to attend the **Bid Opening Meeting & sign the Bid Document** (*tick wherever applicable or tick both, if same person is to attend*) to be held on..... at MANIREDA on behalf of our company.

He is also authorized to provide clarifications/confirmations, if any, and such clarifications/confirmations shall be binding on the company. The specimen signature of is attested below.

.....

(Specimen Signature)
Name :
.....

(Signature of Authorized Signatory)
Name : Designation:
Designation :
Company Seal :

Yours faithfully,

(Signature of Authorized Signatory)
Name :
Designation :

Note:

1. To be submitted by bidders on official letter head of the company.

9. Proforma – 3

Information about the Bidding Firm

NIB No.: MANIREDA/SPP/DC/2019-20/16

Date:.....

SI.	Particulars	
1.	Name of the Bidder	
2.	Address of Bidder with Telephone, Fax, email	
3.	Address of the Registered Office	
4.	Address of the works	
5.	GPS Co-ordinate of Registered Office	
6.	GPS Co-ordinate of Factory Campus	
7.	Name & Designation of Authorized Signatory for Correspondence	
8.	Nature of Firm (Proprietorship/Partnership /Pvt. Ltd./Public Ltd. Co./Public Sector)	
9.	Permanent Account Number (PAN)	
10.	Firm's Registration Number	
11.	EPF Registration No. (if applicable)	
12.	GST Registration Number	
13.	Specify the Item Originally Manufactured	
14.	Year of Starting of Manufacturing/ Assembling of PV Component(s)	
15.	Installed Capacity for Solar Products/ Components/Plant	
16.	Name of Material and Model Type Offered	
17.	Name of Manufacturer of SPPs with Full Address	
	1. Control Electronics/Inverter/PCU	
	2. Battery Bank	
18.	Particulars of Earnest Money	
19.	Quantity Quoted for Solar Power plant	
20.	Name of the Test Center where the testing of Components SPP has been performed	
21.	Test Report No. of components SPP mentioning date of test	
22.	Specify MNRE specification as in the test report	
23.	Place where Materials will be Available for Inspection	

24.	Whether the Bidder has submitted details with regard to supplies made to important organizations.	
25.	Details of any existing service network in Manipur (Name & address of service centre)	
26.	Other details and remarks, if any	

Yours faithfully,

(Signature of Authorized Signatory)

Name : Designation
: Company seal
:

(Separate sheet may be used for giving detailed information in seriatim duly signed. This bid proforma must be submitted duly signed in case separate sheet is submitted).

10.Proforma – 4

Details of Orders Received and Executed in Past Years

NIB No.: MANIREDA/SPP/DC/2019-20/16

Date:.....

Details of Orders Received & Executed by the Manufacturer/Supplier for Supply of SPPs to SNA/
Govt. Organization/ Govt. Deptt. during past Years.

Sl. No.	Name of Agency/ Organization	Purchase Order No., Date & Ordered Qty.	Name of Model	Delivery Schedule	Qty. Supplied Within Delivery Schedule	Qty. Supplied After Delivery Schedule	Date of Full Supply

Yours faithfully,

(Signature of Authorized Signatory with
Name Designation & Company Seal)

Note:

- (a) Attach Photocopies of Purchase Orders
 - (b) Attach Photocopies of Certificate of Satisfactory Performance Issued by Concerned Agency/Organization
 - (c) Separate sheet may be used for giving detailed information in seriatim duly signed.
- This bid proforma must be submitted duly signed in case separate sheet is submitted

11.Proforma – 5

No Deviation Certificate

NIB No.: MANIREDA/SPP/DC/2019-20/16

Date:.....

To,

The Director
Manipur Renewable Energy Development Agency (MANIREDA),
2nd Floor, South Block, Secured Office Complex, AT Line, Near Imphal Hotel,
Imphal-795001.

Dear Sir,

We understand that any deviation/exception in any form from our bid against the above mentioned reference number may result in rejection of our bid.

We, therefore, certify that we have not taken any exceptions/deviations anywhere in the bid and we agree that if any deviation is mentioned or noticed, our bid may be rejected.

Yours faithfully,

(Signature of Authorized Signatory)

Name :

Designation :

Company seal :

Note : This "No Deviation Certificate" should be written on the letter head of the bidder indicating BID No. duly signed and stamped with date by a person competent and having the power of attorney to bind the bidder.

12. Proforma – 6

Format for Guarantee Card

NIB No.: MANIREDA/SPP/DC/2019-20/16

Date:.....

(To be supplied by bidders on the official letter head of the company/firm)

Guarantee Card

	Name & Address of the Manufacturer/ Supplier of the System	
	Name & Address of the Purchasing Agency	
	Date of Supply of the System	
	Details of Inverter Supplied in the System	
	Name of the Manufacturer	
	Make	ABB
	Model	MGS100-15
	Serial No.	
	Month & Year of Manufacture	
	Guarantee Valid Upto	
	Details of Battery Bank	
	Name of the Manufacturer	
	Make	
	Model	
	Serial No(s).	
	Month & Year of Manufacture	
	Guarantee Valid Upto	
	Designation & Address of the Person to be Contacted for Claiming Guarantee Obligations	

(Signature of Authorized Signatory with Name,
Designation & Company Seal)

13. Proforma – 7

Format of Completion Certificate

Office of the
MANIPUR RENEWABLE ENERGY DEVELOPMENT AGENCY (MANIREDA)

(An Autonomous Govt. Agency under the Department of Power)

2nd Floor, South Block, Secured Office Complex, A.T. Line, Near Imphal Hotel, Imphal – 795001, Phone: 385-2444027

TO WHOM IT MAY CONCERN

Imphal, dated

No.: 58/1/2009/SADP/MANIREDA/Pt-I: This is to certify that M/s has Executed the project of Renovation of existing 9 Nos. of 25 kWp Off-Grid SPV Power Plants at 9(nine) Deputy Commissioners' offices in Manipur including 5 years Maintenance and Performance Warranty Contract (MPWC).
as follows;

Sl. No	Work Order No. & Date	Site Address	Type of System	Capacity	Qty.	Date of Completion
1.		9 Deputy Commissioners offices in Manipur.	Off- Grid SPV Power Plant.	135 (15 kW x 9)	9 No.

Work Order Value	Rs.
Executed Work Value	Rs.

The installed grid connected SPV power plant is operating satisfactory.

(L. Manglem Singh)
Director

Copy to:

- (i) M/s(Installing Firm)
- (ii) Guard file.

14. Proforma – 8

PRICE SCHEDULE/FINANCIAL BID Renovation of existing 9 Nos. of 25 kWp Off-Grid SPV Power Plants at 9(nine) Deputy Commissioners' offices in Manipur including 5 years Maintenance and Performance Warranty Contract (MPWC).

NIB No.: MANIREDA/SPP/DC/2019-20/16

Date :

To,
The Director
Manipur Renewable Energy Development Agency (MANIREDA),
2nd Floor, South Block, Secured Office Complex, AT Line, Near Imphal Hotel, Imphal-795001.

A. PRICE SCHEDULE

for Supply, Installation & Commissioning of 15 kW SPV Power Plant at 9 DC offices in Manipur

Sl. No.	Item	Unit	Total Bid Qty.	Rate (Rs.)	Amount (Rs.)
1.	Project Cost for Renovation of existing 9 Nos. of 25 kWp Off-Grid SPV Power Plants at 9(nine) Deputy Commissioners' offices in Manipur including 5 years Maintenance and Performance Warranty Contract (MPWC).	Set	9		
2.	Materials Cost for Renovation of existing 9 Nos. of 25 kWp Off-Grid SPV Power Plants at 9(nine) Deputy Commissioners' offices in Manipur including Supply of new Micro Grid Inverters (15 kW, Make-ABB), supply of new Battery Banks (48V 500 Ah)(24 Nos. of 2V 500Ah for each Plant), supply of maximum of 10 Nos. of SPV Modules and other necessary accessories etc. @ 70% of SI. No. 1.	Set	9	(Locked Cell)	70% of SI. No.1. (Locked Cell)
3.	Installing and Commissioning Cost @ 15% of SI. No. 1.	Set	9	(Locked Cell)	15% of SI. No.1. (Locked Cell)
4.	MPWC Cost for 5 yrs. @ 15% of SI. No. 1.	Set	9	(Locked Cell)	15% of SI. No.1. (Locked Cell)
5.	GST 5% on SI. No. 2.	Set	9	(Locked Cell)	(Locked Cell)
6.	GST 18% on SI. No. 3.	Set	9	(Locked Cell)	(Locked Cell)
7.	GST 18% on SI. No. 4.	Set	9	(Locked Cell)	(Locked Cell)
8.	Work Order Value to the Firm SI. Nos. (1+5+6+7)	Set	9	(Locked Cell)	(1+5+6+7) (Locked Cell)
9.	State Govt. Charges:				
10.	Labour Cess @1% on SI. No. 3.	Set	9	(Locked Cell)	(Locked Cell)
11.	Contingency Charge @3% on SI. No. 3.	Set	9	(Locked Cell)	(Locked Cell)
12.	Contingency Charge @3% on SI. No. 4.	Set	9	(Locked Cell)	(Locked Cell)
13.	Agency Charge @ 11.75% on SI. No. 3.	Set	9	(Locked Cell)	(Locked Cell)
14.	Grand Total SI. Nos. (8+10+11+12+13)	Set	9	(Locked Cell)	(8+10+11+12+13) (Locked Cell)

- **N.B.: Lowest Bidder (L1) shall be accepted for this Price Bid.**

B. PRICE SCHEDULE
for Disposal of Old Battery Bank and PCU/Inverters at the existing condition in 9 DC offices of Manipur.

Sl. No.	Item	Type and Capacity	Make, Model and Mfg yr.	Unit	Total Bid Qty.	Rate (Rs.)	Amount (Rs.)
1.	Disposal of Old Battery Bank	Flooded type Lead Acid Battery Bank of capacity 240V 1000 Ah (120 Nos. of 2V 1000 Ah Battery at each DC office).	Make: HBL Power systems Ltd., Model: Taurus (T1000H) & Mfg yr.: 2011	Set	9		
2.	Disposal of Old PCU/Inverters	Off-Grid PCU/Inverter of capacity 25 kW at: 1. DC office, Ukhrul 2. DC office, Senapati 3. DC office, Thoubal 4. DC office, Bishnupur 5. DC office, Chandel 6. DC office, Ccpur 7. DC office, Imphal West 8. DC office, Imphal East 9. DC office, Tamenglong	Make: Emerson India. Model: Liebert ESU 30 kW 030-Bidirectional Mfg yr.: 2011 Make: Optimal Power Synergy, India. Model: GSC-25K (3P-0D-230-50-240-25K)MPPT Mfg yr.: 2011	Set	9		
3.	Total Cost Sl. No. (1+2)			Set	9	(Locked Cell)	(Locked Cell) Sl. No. (1+2)

* N.B.: The Quoted Amount for Disposal of Old Battery Bank should be more than Rs. 17,28,000/- @ Rs. 1,92,000/- per site.
The Quoted Amount for Disposal of Old PCU/Inverters should be more than Rs. 3,37,500/- @ Rs. 37,500/- per site.
If quoted less then the Tender is liable to be rejected.

• **N.B.: Highest Bidder (H1) shall be accepted for this Price Bid.**

(SUBMIT THE FINANCIAL BID ONLINE ONLY)

Yours faithfully,
(Signature of Authorized Signatory)
Name:
Designation:
Company Seal:

15. Proforma- 9
(On the Letter Head of the Firm)

PROFORMA OF APPLICATION FOR PAYMENT
--

Unit Reference:	Date:
Name of Contractor:	Contract No.:
Contract Name :	
Application Serial Number. :	Contact Value :

To,
The Director
Manipur Renewable Energy Development Agency (MANIREDA),
2nd Floor, South Block, Secured Office Complex, AT Line, Near Imphal Hotel,
Imphal-795001.

Dear Sir,

APPLICATION FOR PAYMENT

Pursuant to the above referred Contract datedthe undersigned hereby applies for payment of the sum of (Specify amount and currency in which claim is made).

9. The above amount is on account of :[TICK whichever is applicable]

- Initial advance
- Interim Payment as advance
- Progressive payment against dispatch of equipment
- Progressive payment against receipt of equipment at site
- Progressive payment against Erection/installation & commissioning/testing
- Ocean freight & marine insurance
- Inland transportation
- Inland insurance
- Price adjustment
- Extra work not specified in Contract
- (Ref. Contract Change order No.....) Other (specify)
- Final payment

As detailed in the attached Schedule (S) which form an integral part of this application.

10. The payment claimed is as per item(s) No.(s) of the payment schedule annexed to the above – mentioned Contract.

11. The application consists of this page, a summary of claim statement and the following signed schedule

- i).....
- ii).....
- iii).....

The following documents are also enclosed

- a).....
- b).....
- c).....

Signature of Contractor/
Authorised Signatory.

16. Proforma-10

MATERIALS INSPECTION CLEARANCE CERTIFICATE (MICC)
--

1. Name of the Work: Renovation of existing 9 Nos. of 25 kWp Off-Grid SPV Power Plants at 9(nine) Deputy Commissioners' offices in Manipur including 5 years Maintenance and Performance Warranty Contract (MPWC).
2. Name of Worksite/Location: 9(nine) Deputy Commissioners' offices in Manipur.
3. Name of the Firm/Contractor: :
4. Work Order No.: dated
5. Shipment No.....
6. Date shipped:.....,
7. Shipped From
8. Shipped To Imphal

SL. No.	Item Description	Qty./ system	Invoice No. & date	Challan No. & date	Make	Unit price	Amount	Remarks
1	2	3	4	5	6	7	8	9

9. Enclosed documents: Packing List with model numbers, Invoice, Challan, Goods Consignment Note, Way Bill etc.

10. Inspected on:and jointly by MANIREDA officials and representative of M/sand found okay.

Date:
Name:
Designation: Scheme Officer

Signature of authorized MANIREDA representative

18. Check List & Format for Submission of Bid

The following information/documents are to be annexed and flagged by the bidders along with the BID

Sl. No.	Annexure and Proforma No.	Particulars	Yes/No, Flag No.	To be done
1.	Annexure-I	Details of EMD & CMD (D.D from any nationalized bank and validity for at least 3 months from the last date of submission of bids)		Hard copy
2.	Annexure-II	Test Report of PCU/Inverter		Hard copy
3.	Annexure-III	Test Report of Battery		Hard copy
4.	Annexure-IV	Company Warranty Certificate of Battery/Battery Bank to be supplied for a period of 5 years from the Battery Manufacturer.		Hard copy

5.	Annexure-V	A copy of valid GST registration Certificate		Hard copy
6.	Annexure-VI	A summarized sheet of cumulative experience of the bidder of Design, supply, erection, testing, I&C of solar power plants including I&C of a minimum of 15 kWp SPV Power Plant whose work order should be in the name of the bidder.		Hard copy
7.	Annexure-VII	Overall Average Annual Turnover of the Company/Firm/Corporation in the last 3 financial years (A summarized sheet of turnover of last 3 Financial Years certified by registered CA)		Hard copy
8.	Annexure-IX	The bidder has ISO 9001 certification		Hard copy
9.	Annexure-X	The bidder has ISO 14001 certification		Hard copy
10.	Annexure-XII	Demand Draft for cost of bid document/Photocopy of Demand Draft		Hard copy
11.	Annexure-XIII	Letter of acceptance to furnish the true information in Proforma – 3, Proforma – 4 & Proforma – 5.		Hard copy
12.	Annexure-XVI	Copy of audited Balance Sheet and Profit & Loss Account for last 3 (three) years		Hard copy
13.	Annexure-XVIII	A tentative overall supply schedule in the form of Bar Chart		Hard copy
14.	Proforma – 1	Forwarding Letter		Hard copy
15.	Proforma – 2	Authority Letter for Attending Bid Opening Meeting and Signing Bid Document.		Hard copy
16.	Proforma – 3	Information about the Bidding Firm		Hard copy
17.	Proforma – 4	Details of Orders Received and Executed in Past Years		Hard copy
18.	Proforma – 5	No Deviation Certificate		Hard copy
19.	Proforma - 8	Price Bid		Hard copy

Please ensure:

1. That all information is provided strictly in the order mentioned in the check list mentioned above.
2. Note that this is a zero deviation tender. Bidders are advised to strictly confirm compliance to bid conditions and not to stipulate any deviation/conditions in their offer. Subsequent to bid submission, MANIREDA may or may not seek confirmations/clarifications and any offer(s) not in line with Bid conditions shall be liable for rejection.
3. Any clarification/confirmation bidder may require shall be obtained from MANIREDA before submission of the bid.
4. Bidder shall submit complete bidding document including subsequent amendment, modification and revision, duly signed and stamped as a token of having read, understood and accepted all the terms and condition mentioned therein.

..... End of the Bid Document