

**NOTICE**

Dated: Imphal, the 12<sup>th</sup> June, 2020.

No.62/03-II/2018/ RT(Pvt)/Firms/MANIREDA: Attention is sought from Empanelled Firms, towards the Technical Specifications prescribed by the MNRE, GoI & Programme Guidelines issued by MANIREDA w.r.t. implementation of GCRTS, wherein it is clarified that the "**PV module mounting/array Structures including the fasteners should be able to withstand wind speed upto 150km/hour**".

It is therefore, reminded to all the concerned Firms, to ensure that the array structures including its fasteners installed at various plants/work sites, should be able to survive wind speed upto 150km/hour. The Empanelled Firms, shall be liable for damage to the PV modules & arrays, due to wind within the above prescribed speed limit.

Sd/-  
(L. Manglem Singh)  
Director

Copy to:

1. The P.S. to Hon'ble Chairman, MANIREDA,
2. The Member Secretary, MANIREDA,
3. The DEO, MANIREDA,  
- for information to all the Empanelled Firms of GCRTS,
4. The ACO, MANIREDA to upload the Notice in the website of MANIREDA for public information,
5. Guard File.